

# Fluke 362 Clamp Meter

Ready to go wherever your work takes you.

## Technical Data

The new Fluke 362 Clamp Meter is designed to fit easily in your pocket. The small 18 mm triangular jaw allows access into tight places where other clamp meters can't reach, while providing the accuracy you can trust from a Fluke tool. This durable clamp meter is a must-have for basic clamp measurements.

### Features

- Thin, light, compact body design for one-hand operation
- 18 mm triangular jaw allows for easy measurement on small cables
- Large, easy-to-read display for easy viewing
- 200 A ac and dc current and 600 V ac and dc voltage measurement range
- 3000  $\Omega$  resistance range, continuity detection
- Zero function allows the display to be cleared for dc measurements
- Data hold function
- CAT III 600 V safety rating



## Technical specifications

	Range	Resolution	Accuracy
AC current	200 A	0.1 A	2 % ± 5 digits (45-65 Hz) 2.5 % ± 5 digits (65-400 Hz)
DC current	200 A	0.1 A	2 % ± 5 digits
AC voltage	600 V	0.1 V	1.5 % ± 5 digits (45-400 Hz)
DC voltage	600 V	0.1 V	1 % ± 5 digits
Resistance	300/3000Ω	0.1/1Ω	1 % ± 5 digits
Continuity	≤ 70 Ω		
Data hold	Yes		

## General specifications

Size (LxWxH)	205 mm × 60 mm × 22 mm
Jaw opening	18 mm
Weight	196 g
Safety rating	CAT III 600 V
Warranty	2 years

## Ordering information

### Fluke 362 Clamp Meter

#### Included:

Clamp meter, TL75 test lead set,  
two AAA batteries (installed)  
and user manual.

**Fluke.** *The Most Trusted Tools  
in the World.*

#### Fluke Corporation

PO Box 9090, Everett, WA 98206 U.S.A.

#### Fluke Europe B.V.

PO Box 1186, 5602 BD  
Eindhoven, The Netherlands

#### For more information call:

In the U.S.A. (800) 443-5853 or  
Fax (425) 446-5116

In Europe/M-East/Africa +31 (0) 40 2675 200 or  
Fax +31 (0) 40 2675 222

In Canada (800)-36-FLUKE or  
Fax (905) 890-6866

From other countries +1 (425) 446-5500 or  
Fax +1 (425) 446-5116

Web access: <http://www.fluke.com>

©2013 Fluke Corporation.  
Specifications subject to change without notice.  
Printed in U.S.A. 4/2013 4333185A\_EN

**Modification of this document is not permitted  
without written permission from Fluke Corporation.**